

Statement of work

For

American Consulate Wuhan

1. Introduction

- To provide UPS (Uninterrupted Power Supply) to individual PC.

2. Location of Service

- The deliver and install UPS at the following address:
5th – 6th floor of Minsheng Bank Building individual's desk
No.396 Xinhua Rd, Jiang'an Dis., Wuhan

3. Service Content

- Minimum capacity: 750VA
- Operating Input Voltage range: minimum 200-260V,
- Nominal Input Frequency: 50/60Hz plus or minus 3HZ, auto adapting
- Output voltage: 220V
- Topology: line interactive
- Output waveform: pure sine wave
- Output: Minimum of 6 IEC 320 C13
- Input: IEC 320 C14 replaceable cable
- User replaceable batteries
- Automatic Voltage Regulation – boost and trim without battery usage
- Power conditioning – including surge, spike protection
- After UPS shutdown due to power failure, automatic restart upon restoration of power
- Battery management and predictive failure capability
- Vendor should provide enough IEC 320 C13 to IEC 320 C14 cables to fully populate the UPS
- Safety requirement: Ensure safety and stability, no electrician shock risk
- Period of Performance: From the date of the notice to proceed, the contractor has 15 working days to fulfill the terms of the contract.

SOW 工作内容概要

1.简介

美国驻武汉总领事馆现需要安装不间断电源到电脑

2.服务地点

服务商将运送至如下地点并提供不间断电源的安装服务。

湖北省武汉市江岸区新华路 396 号民生银行大厦 5-6 楼电脑区域

3.服务内容

- 最小容量: 750VA
- 工作输入电压范围: 最少 200-260V,
- 标称输入频率: 50 / 60Hz 正负 3HZ, 自动适配
- 输出电压: 220V
- 拓扑: 交互式布线
- 输出波形: 纯正弦波
- 输出: 最低 6 IEC 320 C13
- 输入: IEC 320 C14 可更换电缆
- 用户可更换电池
- 自动电压调节 - 无需电池即可进行升压和微调
- 功率调节 - 包括浪涌, 尖峰保护
- 停电引起的 UPS 关机, 可在电力恢复后自动重启
- 电池管理和预测性故障功能
- 供应商应提供足够的 IEC 320 C13 至 IEC 320 C14 电缆, 完全保证 UPS 的使用
- 安全要求: 确保稳定性和安全性, 无触电风险
- 安装周期: 从接到施工通知的第一时间起, 供应商需在 15 个工作日内履行完合同条款。